


**INSPECTION AREA  
DATA LOG RESULTS**



From : 03/06/2013 11:16  
 To : 10/06/2013 11:01  
 Duration : 6 days 23 hours 45 minutes 21 seconds  
 Interval : 15 minutes  
 Data Points : 671

Item :	Current (amps)	Energy (kWh)	Power (kW)	Cost (£)	CO2 (kg)
Mean Value :	7.9	0.5	1.9	0.05	0.3
Median Value :	8.2	0.5	2	0.05	0.3
Maximum Value :	9.2	0.6	2.2	0.05	0.3
Time of Maximum :	09/06/2013 19:30	09/06/2013 19:30	09/06/2013 19:30	09/06/2013 19:30	09/06/2013 19:30
Minimum Value :	7.1	0.4	1.7	0.04	0.2
Time of Minimum :	03/06/2013 14:45	03/06/2013 14:45	03/06/2013 14:45	03/06/2013 14:45	03/06/2013 14:45
Mean to Peak Ratio :	0.9	0.9	0.9	0.86	0.9
Standard Deviation :	0	0	0	0	0
Overall Value :	7.9	319.2	1.9	<b>£31.32</b>	179.4

From : 20/06/2013 16:41  
 To : 27/06/2013 16:19  
 Duration : 6 days 23 hours 38 minutes  
 Interval : 10 minutes  
 Data Points : 1005

Item :	Current (amps)	Energy (kWh)	Power (kW)	Cost (£)	CO2 (kg)
Mean Value :	1.6	0.1	0.4	0.01	0
Median Value :	2.7	0.1	0.7	0.01	0.1
Maximum Value :	5.5	0.2	1.3	0.02	0.1
Time of Maximum :	27/06/2013 02:20	27/06/2013 02:20	27/06/2013 02:20	27/06/2013 02:20	27/06/2013 02:20
Minimum Value :	0	0	0	0	0
Time of Minimum :	20/06/2013 16:50	20/06/2013 16:50	20/06/2013 16:50	20/06/2013 16:50	20/06/2013 16:50
Mean to Peak Ratio :	0.3	0.3	0.3	0.3	0.3
Standard Deviation :	0.1	0	0	0	0
Overall Value :	1.6	65.5	0.4	<b>£6.42</b>	36.8

**SAVING 79.5%**